



Follow Apollo's pipe rack, supplement it with unistrut in order to meet our code support requirements:

- 3/4" Conduit: 10'
- 1" Conduit: 12'
- 1-1/2" Conduit: 14'

Apollo to provide the heat trace tape, we install it.

Rooms 1220 and 1222 Floor Plans

Scale: 1"=8'