



Note: This drawing shows a revised footprint for panels MPH-1 and SDPH-1. My vendor tells me that this happened when he saw the latest riser diagram. I tightened up the equipment on the east wall in Room 1220 for that (pushed it to the south and removed the gap between them), and pushed everything eastward on the north wall or Room 1222 to make room for the larger switchboard. I also moved the doors in Room 1222, to try to free up wall space. The riser diagram shows some panels in this room that the enlarged floor plans don't: SLPH-1C, SLP-1C, and the transformer between them - STK-1C. They are the reason why I moved the low voltage panels around - to try to free up some wall space. Can they (the low voltage panels) be put into another room?

Note that the door is right against the GSP panel, which leaves no room for a light switch. In one of my earlier drawings, I moved the door north. When I attached the latest floor plan as an X-Ref, I noticed it was in its original location. Can it either be moved north, or the swing reversed?

Electrical Rooms 1220 & 1222

Scale: 1/4" = 1'